

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:36 pm

PWS ID: UTAH22021 **Name:** HIGH VALLEY WATER CO

Legal Contact: HIGH VALLEY WATER CO **Rating:** Approved
KAREN SAWYER **Rating Date:** 11/18/1986

Address: PO BOX 3435 **Activity Status:** Active
PARK CITY, UT 84060

Phone Number: 435-645-8415

City Served (Area):

County: SUMMIT COUNTY

System Type: Community **Last Inv Update:** 07/06/2011 **Avg Daily Prod:**

Activity Status Cd: Active **Last Snty Srv Dt:** 10/20/2008 **Total Dsgn Cap:**

Population: 850 **Surveyor:** ELDEN L OLSEN **Total Emerg Cap:**

Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Office Phone Numbers	Emergency	Email Address
AC	SAWYER, KAREN		435-645-8415	435-658-0037	sawyerkb@comcast.net

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Metered	0	232
			232 Total Svc Connections

Storage

Total Storage: 500,000 GAL **Number of Units:** 1 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	STORAGE FACILITY ST001	Ground	500,000 GAL	Steel		A	

Pumping Stations

Facility No	Facility Name	Activity Status	Capacity	Avail	Emerg Power	Operating Category	Total Dynamic Head
PF001	HIGH VALLEY PUMPING FACILITY	A		P			

Distribution System

Pump Type	Total Dyn Head ft H2O P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	HIGH VALLEY OLD WELL	Active	WL	10	150 GPM	150 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS002	ATKINSON #2 WELL	Inactive	WL	10	100 GPM		Yes	GW	Permanent		
WS003	REPLACEMENT WELL	Inactive	WL				Yes	GW	Other		
WS004	UTAH22059 SUMMIT WATEF	Active	CC				No	GW	Permanent	1/1 to 12/31	
WS005	UTAH22109 MOUNTAIN REC	Inactive	CC				No	SW	Permanent		

*Reports measured flow for wells, approved design capacity for all other sources.